

Product certificate number

No: 2613/1139/E6-CER

Manufacturer

Fronius International GmbH
Fronius Straße 5, A-4642 Sattledt, Austria



Trademark



Model

Fronius SYMO 3.0-3-S / Fronius SYMO 3.7-3-S / Fronius SYMO 4.5-3-S

Type of generating unit **Static Power Converter**

Technical Data

Nominal Power	3 kW	3,7 kW	4,5 kW
Rated Voltage	230 V		
Nominal Frequency	50 Hz		

Firmware version

RECERBO: V0.3.23.0
Power Stage: V1.2.11.1
Filter: V0.9.24.1

Number of phases
Isolation Transformer

Three phase
No

Standard

IEC 62116:2014. Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.

The above-mentioned generating unit is certified according the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate cancels and supersedes certificate number 2613/1139/E5-CER.

This certificate is valid until: 4th of May 2022. First issued on 22th of November of 2013.

Madrid, 03rd of February 2020

Daniel Arranz Muñiz
Certification Manager

